NAVAL AIR WARFARE CENTER, TRENTON, NJ

Groundwater Treatment Facility Operations And Maintenance

MONTHLY REPORT

March 1996


1.	Total volume of groundwater pumped for the month.	416,600 gal.
2.	Total number of shutdowns for the month Shutdown details listed below.	8
	Four shutdowns were due to excessive pressure differential across the bag filter unit, which was corrected by changeout of the bag filter. One shutdown was due to excessive pressure differential across the sand filter. The sand filter is currently being bypassed until biological analyses are conducted. Three shutdowns occurred due to a failed relay in the control panel. The relay was replaced on March 20,1996.	
3.	Total liquid phase carbon changeouts for the month	0

NOTES:

- 1. The influent pH of the system was not adjusted due to iron results that were below ELSA discharge requirements.
- 2. After it is unclogged the sand filter will return to service.
- 3. Treated groundwater was discharged to ELSA beginning March 4, 1996.


Foster Wheeler Environmental Corporation

Naval Air Warfare Center (NAWC) - Trenton, NJ Groundwater Treatment System




Foster Wheeler Environmental Corporation

Naval Air Warfare Center (NAWC) - Trenton, NJ Groundwater Treatment System



Two hyl Chloride results (2 ppb and 5 ppb) for Sampling Point 8 (Post on Unit 2) were observed in March. Effluent results were consisted. Non-Detect for the month of March. Results for trans-1,2-DCE were non-detect for the month of March.

Naval Air Warfare Center (NAWC) - Trenton, NJ Groundwater Treatment System



Foster Wheeler Environmental Corporation

Naval Air Warfare Center (NAWC) - Trenton, NJ Groundwater Treatment System

